

WELL INSPECTION REPORT

ADWR Well Registration No.: 55-227957
Well type: Exempt

Date drilled: 3-22-2018
Date of inspection: 4-20-2018

Drilled and inspected by: R. Davis Drilling LLC
PO Box 1427
Springerville, AZ 85938
(928) 245-0603

Well owner: James W. Crosswhite Trust
Landowner: EC Bar Ranch LLC
PO Box 32017, Tucson, AZ 85751
(928) 339-4840

Well location: House 20, CR2112, Nutrioso, AZ
N33*58.386', W109*12.123'
T7N, R30E, S29, NE¼, SW¼, SW¼
Parcel ID #: 102-66-068 Apache County

Primary Use: Domestic

Casing type and diameter: Surface seal: 6" steel. Well: 6" steel, perforated 60-80 ft

Total well depth: 103 ft (0-67 ft clay/silt), 65-80 ft (sand/gravel/water), 80-103 ft (clay)

Static water level: 40 ft

Pump rating (HP and flow): 1 HP 10 gpm Gould pump on 1" PVC pipe set at 70 ft

Pressure tank capacity: 86 gallon tank

Overall mechanical condition: Operational on 220 volts

Overall visual condition: OK

Well flow rate: 10 gpm

Total well drawdown: 10 feet

Clarity of water: clear

Additional Remarks: Flow tested from faucet



1. Drilling well on 0.21 acres



2. Drilling well



3. Drilling well